



# HAYWARD INDUSTRIAL PRODUCTS

## BUTTERFLY VALVE

### INSTALLATION, OPERATION AND MAINTENANCE INSTRUCTIONS

**PLEASE READ THE FOLLOWING INFORMATION PRIOR TO INSTALLING AND USING HAYWARD VALVES, STRAINERS, FILTERS, AND OTHER ASSOCIATED PRODUCTS. FAILURE TO FOLLOW THESE INSTRUCTIONS MAY RESULT IN SERIOUS INJURY.**

1. Hayward guarantees its products against defective material and workmanship only. Hayward assumes no responsibility for damage or injuries resulting from improper installation, misapplication, or abuse of any product.
2. Hayward assumes no responsibility for damage or injury resulting from chemical incompatibility between its products and the process fluids to which they are subjected. Compatibility charts provided in Hayward literature are based on ambient temperatures of 70° F and are for reference only. Customer should always test to determine application suitability.
3. Consult Hayward literature to determine operating pressure and temperature limitations before installing any Hayward product. Note that the maximum recommended fluid velocity through any Hayward product is eight feet per second. Higher flow rates can result in possible damage due to the water hammer effect. Also note that maximum operating pressure is dependent upon material selection as well as operating temperature.
4. Hayward products are designed primarily for use with non-compressible liquids. They should NEVER be used or tested with compressible fluids such as compressed air or nitrogen.
5. Systems should always be depressurized and drained prior to installing or maintaining Hayward products.
6. Temperature effect on piping systems should always be considered when the systems are initially designed. Piping systems must be designed and supported to prevent excess mechanical loading on Hayward equipment due to system misalignment, weight, shock, vibration, and the effects of thermal expansion and contraction.
7. Because PVC and CPVC plastic products become brittle below 40° F, Hayward recommends caution in their installation and use below this temperature.
8. Published operating torque requirements are based upon testing of new valves using clean water at 70° F. Valve torque is affected by many factors including fluid chemistry, viscosity, flow rate, and temperature. These should be considered when sizing electric or pneumatic actuators.
9. Due to differential thermal expansion rates between metal and plastic, transmittal of pipe vibration, and pipe loading forces **DIRECT INSTALLATION OF METAL PIPE INTO PLASTIC CONNECTIONS IS NOT RECOMMENDED**. Wherever installation of plastic valves into metal piping systems is necessary, it is recommended that at least 10 pipe diameter in length of plastic pipe be installed upstream and downstream of the plastic valve to compensate for the factors mentioned above.

#### INSTALLATION

Hayward Butterfly Valves should be installed between two pipe flanges. In dead end service, it is recommended they be installed between one pipe flange and a downstream companion or blind flange. The use of additional gaskets is not necessary and not recommended.

When installed between two existing flanges, the flanges should be separated to provide clearance on the face to face of the valve. This will prevent the valve sealing surfaces from distortion during installation. Pipe flanges should be clean and, free of debris including old gasket material. A light coating of a lubricant such as “Non-Fluid Oil” #666 applied to the flange sealing-surface will aid in installation.

Hayward Butterfly Valves are designed for use with all pipe flanges that have bores equal to or larger than Schedule 80 pipe (Schedule 40 pipe for 14”-24” valve) as listed below. The inside of the pipe flange must be chamfered at a 45 degree angle to a diameter listed if the inside bore is smaller than listed. Sharp edges and burrs must be removed.

Valves can be opened to approximately 15° when installed. Do not open fully during installation to prevent damage to the edge of the disc by the mating flanges.

Install the valves using well-lubricated studs or bolts and nuts. For plastic flanges metal washers are recommended between nut/bolt head and pipe flange. With a torque wrench, uniformly tighten nut to approximately 10 foot pounds in an alternating sequence, diametrically opposed to the previously tightened nut. Final tightening should be performed in the same sequence following the recommended torque in the following chart.

For plastic Schedule 80 pipe the maximum allowable displacement is 1/16” off center in any direction. Maximum angular misalignment of 1/32” is allowable.

Normal pipe hanger spacing is recommended. *Do not allow valve to support the weight of pipe.* When using pneumatic or electric actuators, additional support directly to the actuator is recommended.

#### RECOMMENDED FLANGE BOLT TORQUE FOR BUTTERFLY VALVES

Size Nominal	Minimum Pipe / Flange Bore (in.)	Stud Dia (in.) x Length (in.)	Bolt Dia (in.) Thread	Flat Face Type Flange	Van-Stone Type Flange
				Torque Ft * Lb.	Torque Ft * Lb.
1 1/2”	1.45	1/2 x 4.50	1/2 - 13 UNC	10-15	5-10
2”	1.88	5/8 x 4.50	5/8 - 11 UNC	15-25	10-20
3”	2.83	5/8 x 5.00	5/8 - 11 UNC	20-25	10-20
4”	3.75	5/8 x 6.00	5/8 - 11 UNC	20-25	10-20
6”	5.68	3/4 x 6.75	3/4 - 10 UNC	30-40	10-20
8”	7.54	3/4 x 7.50	3/4 - 10 UNC	30-40	20-30
10”	9.47	7/8 x 10.25	7/8 - 9 UNC	50-60	40-50
12”	11.27	7/8 x 11.50	7/8 - 9 UNC	50-60	40-50
14”	13.12	1 x 10.25	1 - 8 UNC	100	N/A
16”	14.35	1 x 12.75	1 - 8 UNC	100	N/A
18”	16.50	1-1/8 x 13.25	1-1/8 - 7 UNC	100	N/A
20”	18.50	1-1/8 x 14.50	1-1/8 - 7 UNC	100	N/A
24”	22.25	1-1/4 x 14.75	1-1/4 - 7 UNC	100	N/A

## OPERATION

When installation is complete, check for proper alignment. Fully open and close the valve 3 or 4 times. With a lever installed, fully squeeze the handle and hold in for the full stroke 90° stroke of the lever. For optimum operation the lever handle should be held up until full stroke of valve is reached. The handle should be relaxed only at end of stroke.

Maximum operation pressure at 70° F is 150 PSI for 2"-10", 100 PSI for 12"-14", 86 PSI for 16", 72 PSI for 18", and 51 PSI for 20"-24" valves.

## MAINTENANCE & DISASSEMBLY OF VALVE

- I. Minimal valve maintenance is required.
- II. Actuator Assembly: Actuators can be removed and installed without removing valve from the line. The line should be depressurized before any actuator is removed.

